
R&S®EMC32/AMS32 EMC Measurement Software OTA Measurement Software Installation Manual





1144.5428.42 - 09

The Installation Manual describes the following R&S[®]EMC32/AMS32 models and options:

- R&S EMC32
- R&S AMS32

COPYRIGHT

Copyright © 2010 by Rohde & Schwarz GmbH & Co KG. All rights reserved.

Information in this document is subject to change without notice. The software described in this document is furnished under a license agreement or nondisclosure agreement. The software may be used or copied only in accordance with the terms of those agreements. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or any means electronic or mechanical, including photocopying and recording for any purpose other than the purchaser's personal use without the written permission of Rohde & Schwarz.

Portions of the software described in this document copyright © of Microsoft Corporation. All rights reserved.

Windows 7®, Windows Vista®, Windows 2000®, Windows XP®, Internet Explorer® and Windows Installer® are trademarks or registered trademarks of Microsoft Corporation in the U.S.A. and other countries. iKey® is a registered trademark of Safenet Inc. Pentium® is a registered trademark of INTEL Corporation.

Other brands and their products are trademarks or registered trademarks of their respective holders and should be noted as such.

The firmware of the instrument makes use of several valuable open source software packages. the most important of them are listed below, together with their corresponding open source license. The verbatimlicense texts are provided on the user documentation CD-ROM (included in delivery).

Rohde&Schwarz would like to thank the open source community for their valuable contribution to embedded computing.

© 2011 Rohde & Schwarz GmbH & Co. KG 81671 Munich, Germany Printed in Germany – Subject to change – Data without tolerance limits is not binding. R&S[®] is a registered trademark of Rohde & Schwarz GmbH & Co. KG. Trade names are trademarks of the owners.

The following abbreviations are used throughout this manual: R&S®EMC32/AMS32 is abbreviated as R&S EMC32/AMS32.

Table of Contents

	Conventions Used in the Documentation	3
1	INTRODUCTION	5
2	Newsletter Service	6
3	Installing R&S EMC32/AMS32	7
3.1	System Requirements	7
3.2	Installation Fundamentals	8
3.2.1	Installation Folder	8
3.2.2	Data Security and User Administration	8
3.3	Software Installation	9
3.3.1	R&S EMC32/AMS32 Installation	9
3.3.2	Driver Installer Tool	13
3.3.3	Network Installation Tips	15
3.3.4	R&S EMC32/AMS32 Data Backup	15
3.4	iKey Software Protection	16
4	Starting the program	17
5	EMC32 Configuration	18
6	AMS32 Configuration	20
7	Upgrading EMC32	21
7.1	EMC32 Product Cross Reference Table	21
7.2	Migrate R&S EMC32/AMS32 Data Folders	22
7.3	Update Procedure	23
8	Uninstalling R&S EMC32/AMS32	24

	Index	28
10	Troubleshooting	27
9	Using the iKey Merge Tool	25

Conventions Used in the Documentation

The following conventions are used throughout the R&S EMC32/AMS32 Installation Manual:

Typographical conventions

Convention	Description
"Graphical user interface elements"	All names of graphical user interface elements both on the screen and on the front and rear panels, such as dialog boxes, softkeys, menus, options, buttons etc., are enclosed by quotation marks.
"KEYS"	Key names are written in capital letters and enclosed by quotation marks.
Input	Input to be entered by the user is displayed in italics.
File names, commands, program code	File names, commands, coding samples and screen output are distinguished by their font.
"Links"	Links that you can click are displayed in blue font.
"References"	References to other parts of the documentation are enclosed by quotation marks.

Other conventions

- Remote commands: Remote commands may include abbreviations to simplify input. In the description of such commands, all parts that have to be entered are written in capital letters. Additional text in lower-case characters is for information only.
- Procedure descriptions: When describing how to operate the device, several alternative methods may be available to perform the same task. In this case, the procedure using the touchscreen is described, where available. Any elements that can be activated by touching can also be clicked using an additionally connected mouse. The alternative procedure using the keys on the device or the on-screen keyboard is only described if it deviates from the standard operating procedures as described in the Quick Start Guide under "Basic Operations".

The terms "**select**" and "**press**" may refer to any of the described methods, i.e. using a finger on the touchscreen, a mouse pointer in the display, or a key on the device or on a keyboard.

R&S EMC32/AMS32 Introduction

1 INTRODUCTION

This document will guide you through the installation process of R&S EMC32/AMS32. You will find the necessary instructions for installation, update, the configuration of the software, the start of the program and tips on installation troubleshooting. If you need further assistance for solving problems during the installation please contact your nearest Rohde & Schwarz Support Center:

ROHDE & SCHWARZ Customer Support Europe

Phone: +49-4129-12345

E-Mail: customersupport@rohde-schwarz.com

ROHDE & SCHWARZ Customer Support America

Phone: 1-888-TEST-RSA (1-888-837-8772) selection 2

E-Mail: customer.support@rsa.rohde-schwarz.com

ROHDE & SCHWARZ Customer Support Asia

Phone: +65 65130 488

E-Mail: customersupport.asia@rohde-schwarz.com

2 Newsletter Service

Before you start using R&S EMC32/AMS32 you should register for the R&S EMC32/AMS32 newsletter service at Rohde & Schwarz website. You will benefit from the registration by receiving information about news and updates of R&S EMC32/AMS32.

Use the following link with a web browser

http://www.rohde-schwarz.com/html/update information system.html

or start the registration dialog via the help menu item ? \rightarrow EMC32 on the Web \rightarrow Newsletter Service. To register in this manner, your computer must be connected to the Internet.

3 Installing R&S EMC32/AMS32

3.1 System Requirements

Before installing R&S EMC32/AMS32 you should check that your computer fulfills the following minimum system requirements:

Operating System

- Windows 7, 32-bit and 64-bit
- Windows Vista (32-bit only)
- Windows XP with SP3 (32-bit only)
- Administrator Access Privileges (during installation)
- CPU: Intel Core models or comparable
- RAM: 1024 MB (Windows XP) or 2048 MB (Windows 7 / Vista)
- Hard Disk Space: at least 500 MB free
- Screen Resolution: at least 1280 x 1024 Pixels, 65536 colors (higher resolution recommended)
- **USB interface**: For using USB measurement instruments Windows XP SP3, Windows Vista or Windows 7 is required.
- **IEEE bus interface**: National Instruments with IEEE488 driver Recommended version is V2.73 (not necessary for demo mode) Compatible cards from other manufactures are not supported!
- Internet Access: The integrated Software Update Manager requires internet access for querying the R&S webpage on updates and important messages (for further information on how to configure the update polling period refer to the EMC32/AMS32 online help).

If your computer does not meet these requirements, the performance of the software may be not ensured.

3.2 Installation Fundamentals

3.2.1 Installation Folder

The following considerations shall give the administrator of the R&S EMC32/AMS32 computer some hints for the selection of the installation location.

The folder structure of R&S EMC32/AMS32 can be split into two sections:

- Executables and device drivers (require only read access during R&S EMC32/AMS32 runtime)
- Data files like configuration and calibration files, test templates and test results (require full file access during EMC32/AMS32 runtime)

Due to security reasons the standard EMC32/AMS32 operator will be logged in the Windows computer as *Standard* or *Power User*. This account will not provide write access to the standard Windows program files folder where the R&S EMC32/AMS32 executables and device drivers will be installed by default.

For solving this issue the setup program allows to define another location for the R&S EMC32/AMS32 data folder (for example "C:\ProgramData\EMC32" or "D:\EMC32", for installations on Windows 7 / Vista the data folder is set to the common application data folder by default). For all R&S EMC32/AMS32 operators the computer administrator must set full read and write access to this folder, to all its subfolders and to all R&S EMC32/AMS32 shortcuts.

3.2.2 Data Security and User Administration

For ensuring the data security of the EMC data files the file protection functions of the Windows operating system have to be used (security section in the Windows file or folder properties dialog).

User administration features inside R&S EMC32/AMS32 are not designed to ensure data security and can therefore only be used to prevent 'Standard Users' from modifying essential settings inside the R&S EMC32/AMS32 (for example the device configuration).

In case R&S EMC32/AMS32 is only operated by few users of comparable knowledge level, it may not be required to use file security features of the operating system. Here the user has to decide, if a user log-in and user list is required and if test data of different users shall be kept in different directories.

For further information on this issue refer to the Online Help chapter *Data Security and User Administration*.

3.3 Software Installation



Both the multiple installation of R&S EMC32/AMS32 and the installation of different R&S EMC32/AMS32 versions on one computer is not possible! If you want to separate EMI and EMS measurements completely, you must follow the instructions in the Online Help, chapter *User Administration* \rightarrow *Different User Profiles.*

If any previous version of R&S EMC32/AMS32 is already installed, then first you have to uninstall that one!


Please also refer to the chapters "Updating R&S EMC32/AMS32" and "Uninstalling EMC32/AMS32".

3.3.1 R&S EMC32/AMS32 Installation

All necessary information for the installation and the installation process of R&S EMC32/AMS32 are provided by the **Autostart** program on the R&S EMC32/AMS32 CD-ROM. Just follow the few easy steps described below and you will have the software installed on your computer, ready to use.

Start of the Installation:


- 1. Close all running programs.
- 2. Insert the **R&S EMC32/AMS32-CD** into your CD-ROM drive. If Autorun is enabled on your system, the installation starts automatically and you can skip steps 3 and 4.
- 3. From the **Start** menu, select **Run**.
- 4. Type **D:\ShowAutoStart.bat** (substitute the correct letter of your CD-ROM drive for **D:**).
- 5. Click on the **Install EMC32/AMS32 Software** button and follow the instructions on the screen (read the license agreement, enter your name and company name).
- 6. The installation program prompts you to select the product which you want to install.
 - **EMC32 EMC Measurement Software**: EMC32 EMC measurement software with EMI and/or EMS section will be installed
 - AMS32 OTA Measurement Software: AMS32 OTA measurement software will be installed.




If you are updating from a previous version > V6.10.20, this dialog will not appear since the setup program has stored your settings in the registry. These settings will appear in the next step as default selection.

7. Select EMC32/AMS32 Software and click on the **Next>** button. In this step you must select the EMC32/AMS32 main applications and the options you want to install. Click on the disk drive or X symbol (₹) to either select an option for installation or remove an option. If you select a main application you can change the installation path for the executables by clicking on the **Change...** button (refer to **Installation Fundamentals** for further information).

If you are upgrading from a version < V8.x please refer to the 'Product Cross Reference Table' in the chapter **Upgrading EMC32/AMS32** for further information about which EMC32/AMS32 options correspond to your product.



8. Click on the **Next>** button and change the path for the installation of the EMC32/AMS32 data (refer to **Installation Fundamentals** for further information). In case of an update, use the path where your R&S EMC32/AMS32 data is located.




When installing on Microsoft Windows 7 / Vista the default data folder path will be set to the system common application data path (for example "C:\ProgramData\EMC32").



By default this folder is not shown in the Windows 7 Explorer.

- 9. Click on the **Next>** button and start the installation process.
- 10. On a successful installation you will receive a confirmation which you can close by clicking on the **Finish** button.
- 11. Alternatively the installation process may be started directly via the command **D:\SETUP.EXE** (substitute the correct letter of your CD-ROM drive for **D:**).
- 12. After the completion of the R&S EMC32/AMS32 main installation the appropriate device drivers have to be installed (e.g. NI-GPIB, VXI Plug & Play or USB driver). For this purpose the *EMC32 Driver Installer Tool* may be started immediately by ticking the *Run Installer for required drivers (VXI, USB)* option. Refer to the next chapter for further information on this tool.






R&S EMC32/AMS32 uses the installation service *Windows Installer 3.1* from Microsoft It is already available on Windows XP with the service pack 3 installed and in the base installations of Windows 7 / Vista. If the Windows Installer is not already installed, it will be installed automatically before R&S EMC32/AMS32 installation is started. In this case the setup program will perform a re-start of the computer and will resume the installation process afterwards.

Please note that for each R&S EMC32/AMS32 application or option an iKey must be available. Otherwise the software can only be operated in demo mode, which means that no devices can be addressed and measurements are only performed in a simulation mode. For demonstration purposes you can use this feature of the software

3.3.2 Driver Installer Tool

The *R&S Driver Installer Tool* is a utility program which allows to install all required USB, VXI plug&play and other device drivers in a sequence. The *Driver Installer Tool* may be started either immediately after the R&S EMC32/AMS32 installation or via the entry in the Rohde & Schwarz program group.

The driver installer tool runs the setup programs from the R&S EMC32/AMS32 CD ROM root folder which may have to be adapted if the CD ROM image location was changed after the initial installation. Before running the installation tick the device drivers which are required for the devices in your system. For further information on the supported devices by R&S EMC32/AMS32 and the required drivers please refer to the list of supported devices in the R&S EMC32/AMS32 CD ROM Auto Start program on the R&S EMC32/AMS32 CD ROM.



If you update EMC32 the R&S Driver Installer Tool will check for installed drivers and thus selects only drivers with older versions installed for updating.



If you add a new device to the R&S EMC32/AMS32 device list which requires a VXI driver you may optionally start the Driver Installer Tool in R&S EMC32/AMS32 from the driver missing warning dialog

If you run an update of R&S EMC32/AMS32 it may be required to update the drivers as well. Thus you see the new version of the driver delivered with this R&S EMC32/AMS32 release in the appropriate column of the driver installer tool.

Some driver may need a Windows restart after installation is completed. In this case you either should postpone the Windows restart action or you must resume the driver installation after this driver manually.

3.3.3 Network Installation Tips

Typically the installation of the R&S EMC32/AMS32 application software should be done in the Program Files folder of your local hard disk. But it is possible to place the R&S EMC32/AMS32 data folder on a network server. Hereby it should be guaranteed that an appropriate network speed is available. Otherwise performance problems in R&S EMC32/AMS32 may appear.

Hence you should first install R&S EMC32/AMS32 on your local hard disk as described above (administrator rights will be required). After this step you can move the paths of the R&S EMC32/AMS32 folders onto the network server. For more details about this item please refer to the chapter *OPTIONS* \rightarrow *File Location* in the EMC32/AMS32 Online Help.

It is required that you have read / write access on the corresponding network drive.

If you are not sure about any of the options, have your system administrator help you with installing R&S EMC32/AMS32.

3.3.4 R&S EMC32/AMS32 Data Backup

The data backup of the measurement data as well as the system configuration is recommended cyclically. Hereby all selected R&S EMC32/AMS32 files are written into a compressed file in the ZIP format.

R&S EMC32/AMS32 therefore provides a utility function which allows to backup or a restore the complete system configuration and measurement results. The backup / restore dialog is opened via File → Backup/Restore

For more details about this item please refer to the chapter **Backup and Restore Data** and **Configuration** in the **EMC32/AMS32 Online Help**.

A CAUTION

You can archive (or move) either individual files or complete tests out of these directories. These files and tests will no longer be accessible by R&S EMC32/AMS32. Moving of important calibration or configuration files may also prevent other tests from being opened or started. For detailed information on the file structure of R&S EMC32/AMS32 refer to the appropriate section of the EMC32/AMS32 online help.

3.4 iKey Software Protection

R&S EMC32/AMS32 is copy protected by a hardlock **iKey** that contains the license information. Before running R&S EMC32/AMS32 with devices, the iKey driver must be installed and the iKey itself be connected to the PC.

The installation of the iKey software is easily started via the R&S Driver Installer Tool (refer to the previous chapters).

Follow the instructions in the setup program. You may need to restart your computer or connect the iKey to a free USB port of your PC during the installation.

You can check the correct functionality of the iKey as follows:

After restarting the computer a utility program appears in the task list called **iKey Token Utility** with which you can check whether the iKey can be detected by the driver. By double clicking on that icon the program is started and the following dialog appears on the screen. If the serial number of the iKey is displayed here, the iKey has been detected correctly.




Figure 3-1 iKey Token Utility Program Dialog



Make sure that the USB interface is activated in the BIOS settings of your computer. The standard installation only supports up to 4 iKeys to be connected at once. Use the **EMC32 iKey Merge Tool** (refer to chapter below) to add EMC32-Kxx options to a EMC32-E/-S main license key in order to reduce the number of iKeys required to run R&S EMC32/AMS32.

4 Starting the program

Once the installation of R&S EMC32/AMS32 is finished, an R&S EMC32/AMS32 icon is displayed on your desktop. Simply double-click it to run the program. You may also start the program from the **Start** button on your Windows desktop.

To launch the program using the Start button:

- 1. Click the **Start** button on your desktop.
- 2. Select Programs → Rohde & Schwarz → EMC32 → EMC32 or Programs → Rohde & Schwarz → AMS32 → AMS32.

Selection of the User Interface Language:

The user interface language of the R&S EMC32/AMS32 can be changed in the R&S EMC32/AMS32 via the dialog *Extras* → *Language...* The new language will be activated after a re-start of EMC32/AMS32.

5 EMC32 Configuration

Before running a measurement with EMC32 the software must be adapted to your system, i.e. you must tell the application which measurement devices are available, through which interfaces these devices may be addressed, how the devices are connected with each other and how a test using this devices should be performed.

A **Configuration Wizard** is available in EMC32 which determines the measurement categories and the measurement instruments available in the system through user queries. Using this information the configuration wizard creates a standard configuration for your system. Correction tables and test templates will also be copied into the appropriate directories. After this step EMC32 is ready to run the first **demo measurement**.

Before the first start of a real EUT measurement the appropriate calibration data for the antennas/transducers and the signal paths have to be entered or calibrated (for more information on this subject refers to the chapter "system calibration" in the online help).

To run the Configuration Wizard perform the following steps:

- 1. Run EMC32 as described in the previous chapter.
- 2. If the start dialog is activated you will find a symbol there to start the configuration wizard.



Figure 5-1 Start Dialog of EMC32

3. You may also start the wizard via the menu entry: Extras → Wizards → Configuration Wizard.

- 4. The following dialog will appear which contains a tab for EMI and/or EMS, depending on the installed main applications.
- 5. In the first step, select the measurement category: radiated and/or conducted.
- 6. In the next step you select the device type which is available in your system for each device class, and set the appropriate interface or interface address.
- 7. After you have completed all your inputs, you may start the configuration process by clicking the button **Finish**.

8.




Figure 5-2 Dialog of the Configuration Wizard (EMI and EMS tab index)




The EMC32 software is now ready for the first start of a demo measurement. Before the first EUT measurement can be performed, a calibration of the signal paths and the input of the antenna and transducer calibration data may be required.

6 AMS32 Configuration

Before running a measurement with AMS32 the software must be adapted to your system, i.e. you must tell the application which measurement devices are available, through which interfaces these devices may be addressed, how the devices are connected with each other and how a test using this devices should be performed.

After the first installation of the AMS32 the data base is empty. For a quick Demo installation, the CD contains a **Standard Data Configuration** which have to be copied to the corresponding directory of the actual AMS32 installation:



Please copy all files of the subdirectories Configuration, Attenuation, OTA Measurements and OTA Auto Test to the corresponding directories of your actual installation. When copying the standard data the AMS32 application should be closed. When starting the AMS32 all the standard data are available.

After this step AMS32 is ready to run the first **demo measurement**.

Before the first start of a real EUT measurement the appropriate calibration data for the antennas/transducers and the signal paths have to be entered or calibrated (for more information on this subject refer to the chapter "system calibration" in the online help).



The AMS32 software is now ready for the first start of a demo measurement. Before the first EUT measurement can be performed, a calibration of the signal paths and the input of the antenna and transducer calibration data may be required.

7 Upgrading EMC32

7.1 EMC32 Product Cross Reference Table

The following cross reference table shows what EMC32 V8 application(s) and option(s) you must install to cover the functionality of a previous product version.

EMC32 Vx Product	EMC32 V8 Product + Options
EMC32-S	EMS32-S EMC32-U6
EMC32-E Plus EMC32-E	EMC32-EB EMC32-K10
EMC32-A+ EMC32-A	EMC32-EB EMC32-K10 EMC32-S EMC32-K1 EMC32-U6 EMC32-K7 (optional)
EMC32-W+ EMC32-W	EMC32-EB EMC32-K10 EMC32-S EMC32-K2 EMC32-U6 EMC32-K7 (optional)
EMC32-C+ EMC32-C	EMC32-EB EMC32-K10 EMC32-S EMC32-U6 EMC32-K7 (optional)

7.2 Migrate R&S EMC32/AMS32 Data Folders

Since EMC32 version 6.10 now allows to fully separating the executable and data folder, you may want to migrate the data folders to the new EMC32/AMS32 data root folder which has been defined during the setup (refer to the chapter R&S EMC32/AMS32 Installation). In that case apply the following steps:

- 1. Before you uninstall the previous version do a backup of all data folders using the Backup utility (refer to the chapter R&S EMC32/AMS32 Data Backup for further information).
- 2. Now update EMC32/AMS32 (refer to the chapter Update Procedure for further information). Update Procedure
- 3. Run EMC32/AMS32 once to complete the setup and close the application.
- 4. In the data root folder open the file <data root folder>\Configuration\EMC32.ini with Notepad or any other text editor.
- 5. Search for the section **[SystemPaths]** where EMC32/AMS32 stores the path information for all data folder (SYSTEM and TESTS). Change the folder path for all lines in this section and save the INI file.
- 6. Run EMC32/AMS32 and restore all data using the EMC32/AMS32 restore function.



If you use the R&S EMC32/AMS32 user login or a split R&S EMC32/AMS32 configuration with several INI files it will be necessary to do the adaptation of steps 4 + 5 for each INI file.

Example:

[SystemPaths]

Tables=C:\Program Files\Rohde-Schwarz\EMC32\System\Tables\
Correction=C:\Program Files\Rohde-Schwarz\EMC32\System\Correction Tables\
LimitLines=C:\Program Files\Rohde-Schwarz\EMC32\System\Limit Lines\
FreqLists=C:\Program Files\Rohde-Schwarz\EMC32\System\Frequency Lists\
Graphic=C:\Program Files\Rohde-Schwarz\EMC32\System\Graphic\
HWSetups=C:\Program Files\Rohde-Schwarz\EMC32\System\Hardware Setups\
TestTemp=C:\Program Files\Rohde-Schwarz\EMC32\System\Test Templates\
CalibTemp=C:\Program Files\Rohde-Schwarz\EMC32\System\Calibration Setups\
Icons=C:\Program Files\Rohde-Schwarz\EMC32\System\Icons\
Tests=C:\Program Files\Rohde-Schwarz\EMC32\System\EUT Information\
ReportSetups=C:\Program Files\Rohde-Schwarz\EMC32\System\EUT Information\
ReportSetups=C:\Program Files\Rohde-Schwarz\EMC32\System\Report Setups\

ReportSetups=C:\Program Files\Ronde-Schwarz\EMC32\System\Report Setups\
Reports=C:\Program Files\Rohde-Schwarz\EMC32\System\Reports\
RefCalib=C:\Program Files\Rohde-Schwarz\EMC32\System\Reference Calibrations\
DeviceList=C:\Program Files\Rohde-Schwarz\EMC32\Execute\Configuration\
EMC32.DeviceList

7.3 Update Procedure

If you update the software, the R&S EMC32/AMS32 system data and test results will not be deleted – the update only replaces the program.



Nevertheless, for the safety of your data we recommend making a backup of all test and calibration data stored in the EMC32 folder. Use the EMC32 backup / restore utility for this purpose (refer to R&S EMC32/AMS32 Data Backup for further information).

For updating R&S EMC32/AMS32, perform the following steps (provided that you have not received other instructions together with the update):

- 1. Run a backup within R&S EMC32/AMS32 to save your existing data.
- 2. Any uninstalling and reinstalling of the iKey software is not required.
- 3. Perform the steps 1 10 from the chapter R&S EMC32/AMS32 Installation. Use the same installation path as used by the currently installed R&S EMC32/AMS32. For the selection of the main applications and options to install refer to EMC32 Product Cross Reference Table above.
- 4. Do **not** run the configuration wizard after a successful update.
- 5. Restore any device driver configuration files if you have changed the original files delivered with the R&S EMC32/AMS32 setup program.

Uninstalling R&S EMC32/AMS32 8

To uninstall R&S EMC32/AMS32 perform the following steps:

- 1. From the Start menu, select Settings \rightarrow Control Panel.
- 2. Double-click on Add/Remove Programs (Software).
- 3. Click the Install/Uninstall tab.
- 4. From the list of programs that you can remove, select **Rohde & Schwarz EMC32**.
- Click Add/Remove.
- 6. In the opened Windows Installer Dialog select **Remove** and confirm that you want to remove the R&S EMC32/AMS32 application (follow the instructions when it asks you to insert the R&S EMC32/AMS32 installation CD-ROM, or press the Cancel button).
 - The uninstall program removes all program files, folders and registry entries which have been installed during the setup process.
- 7. When the files have been removed, the uninstall program indicates that the process is complete. Click on the **OK** button.
- 8. Delete the Rohde-Schwarz folder in the Windows Program Files folder using the Windows File Explorer.

To uninstall iKey software perform the following steps:

- 1. Exit first the program **iKey Token Utility** if this is active in the task bar.
- 2. From the Start menu, select Settings \rightarrow Control Panel.
- 3. Double-click on Add/Remove Programs (Software).
- 4. Click the Install/Uninstall tab.
- 5. Remove the iKey from the USB port.
- 6. From the list of programs that you can remove, select **Rainbow iKey Components**. Click Add/Remove.
- 7. From the list of programs that you can remove, select **Rainbow iKey Driver**. Click Add/Remove.

9 Using the iKey Merge Tool

To reduce the number of required iKeys for running EMC32 the iKey Merge Tool has been installed with EMC32. This tool allows transferring the contents of an EMC32 option iKey EMC32-Kxx or EMC32-Uxx to a main license iKey EMC32-EB or EMC32-S or vice versa.



Combining an EMC32-EB, EMC32-S or AMS32 iKey is not supported by the iKey Merge Tool! Please contact in this case your R&S Support Center

For merging an EMC32-Kxx option iKey to an EMC32-EB or –S main license iKey perform the following steps:



Do not remove an iKey or shutdown your PC when the iKey Merge Tool is running since the contents of the iKeys may be lost. Shut down any running programs.

- 1. Connect both iKeys to your PC (the source and the target iKey).
- 2. Click the **Start** button on your desktop.
- Select Programs → Rohde & Schwarz → EMC32 → Tools → iKey Merge Tool. A dialog will appear.
- 4. In the iKey Merge Tool click on the **Load iKeys** button to read the information stored on both iKeys.




Figure 9-1 Rohde & Schwarz iKey Merge Tool Program Dialog

- 5. Select the option you want to transfer in the table of the source iKey and click on the arrow buttons to move the option to the table of the target iKey.
- 6. Click on the button to **Save Changes to iKeys** to start the transfer process.
- 7. Do not remove any iKey as long as the transfer process is running.
- 8. Close the program after the transfer is completed.
- 9. Store the source EMC32 option iKey as a confirmation of your option license.

10 Troubleshooting

Occasionally, users encounter problems during installation. Here are some troubleshooting tips you can use that may resolve the problem. If you have any further questions, read the Readme file or contact the Rohde & Schwarz Customer Support.

- Before installation, shut down any running programs, including virus-checking programs. Usually, virus-checking software has little or no impact on the installation process; however, if you are running such software and encounter difficulties with your R&S EMC32/AMS32 installation, turning off the virus-checking programs and then re-installing often solves the problem.
- If you receive a message during the installation process that a DLL of Windows is
 used and therefore cannot be updated, quit this message with OK and the installation
 process will be continued (this typically indicates that the latest service pack is not
 installed). Usually this has no further influence on a successful installation of R&S
 EMC32/AMS32.
- Delete any files in your temporary folder. (This folder is determined by the TEMP environment variable. Usually it is located in C:\TEMP or C:\WINDOWS\TEMP.)
- Run a disk scanning utility. Hard drive errors can cause problems with the installation process. (Some Microsoft Windows systems contain a utility named ScanDisk you can use. If you have questions about disk scanning utilities, see your system administrator.)
- Copy the R&S EMC32/AMS32 setup CD to your hard drive, then run SETUP.EXE from your hard drive.
- Check to make sure there was enough free disk space on your hard drive. (The setup process should notify you if there is not enough free disk space prior to installation.)
- Always use in the Regional Options tab-index for Numbers and Currency the Decimal symbol "." instead of ",". Do not use the digit grouping symbol "," (use space character instead).
- A "Hibernating" or Standby" mode of Windows may not be supported by the drivers for the IEEE interface or for the I-Key. Therefore to avoid any possible device driver access errors, such a mode should be deactivated in the Power Control dialog of the Windows control panel.
- Virus scan programs with an active real-time scanning process may decrease the performance of R&S EMC32/AMS32. If possible deactivate this process or exclude R&S EMC32/AMS32 files from this process.
- During the installation R&S EMC32/AMS32 requires full access to the Windows registry key: "HKEY LOCAL MACHINE\Software\Rohde & Schwarz".

Index

A	
Administration	0
C	
CD Installation	08
D	
Data Backup	8
E	
EMC32 Configuration	
1	
iKey	5
Folder	8
Fundamentals	

Network
L
Language 17
N
Newsletter Service 6
0
Online Help 17
S
Starting the program
т
Troubleshooting
U
Uninstalling 24 Update 21 Procedure 23 Update Manager 7 Upgrade 21
W
Wizard